



MELVILLE - May 14, 2002

Siemens Energy & Automation, Inc.
Mr. John Young
5400 Triangle Parkway
Norcross, GA 30092

SUBJECT: Alternate Circuit Breakers

OUR REFERENCE: File E-82615

Dear Mr. Young:

This letter will confirm that UL investigated the suitability of using Murray Type MP-T circuit breakers manufactured by Siemens Energy & Automation as replacements for specific circuit breakers in certain panelboards and circuit breaker enclosures manufactured by other companies. The Type MP-T circuit breakers have been found suitable for use in panelboards and circuit breaker enclosures manufactured by Murray, Arrow Hart, Crouse-Hinds, Cooper Industries, as well as Siemens Energy & Automation. These panelboards and circuit breaker enclosures were manufactured under UL File numbers E-26095 and E-13207 and these file numbers normally appear on the equipment label. The MP-T breakers may be used whenever the equipment label specifies Types MP, MP-A or MP-C circuit breakers.

If you have any questions or comments, please let us know.

Very Truly Yours,

A handwritten signature in blue ink, appearing to read 'Paul Notarian'.

Paul Notarian (X22590)
Senior Staff Engineer

REVIEWED BY

A handwritten signature in blue ink, appearing to read 'Salvatore Porcillo'.

Salvatore Porcillo (X22620)
Engineering Group Leader